

Contaminant	% Reduction	Contaminant	% Reduction
Algae	99.9%	Mercury	93-98%
Aluminum	96-99%	Mold	99.9%
Ameobic Cysts	>99%	Nickel	93-98%
Arsenic	93-98%	Nitrate	85-90%
Asbestos	>99%	Phosphate	93-98%
Atrazine	95%	Potassium	94-97%
Bacteria	>99%	Protozoa	>99%
Barium	93-98%	Radioactivity	93-98%
Calcium	93-98%	Sediment	>99%
Chloride	95-98%	Selenium	94-96%
Chlorine	99.5%	Silicate	85-90%
Chromate	90-95%	Silver	93-98%
Copper	93-98%	Sodium	90-95%
Cryptosporidium Cysts	99.9%	Strontium	96-98%
Cyanide	90-95%	Sulfate	93-98%
Flouride	95-98%	Thiosulfate	96-99%
Giardia Lamblia Cysts	99.9%	Trihalomethene (THM)	98%
Lead	93-98%	Total Volatile Organics	95%
Manganese	93-98%	Zinc	93-98%
Magnesium	93-98%	2,4-D	95%

This list represents only a few of the contaminants removed or reduced by any 4 or 5-Stage Reverse Osmosis Drinking Water System. Results may vary depending upon water conditions, temperature, pressure and whether proper routine maintenance has been performed on the system at appropriate intervals.